

# UBC REAP 3.3 INTERPRETATIONS

Jan 10th 2024

## PROCESS OVERVIEW

- Project teams can submit interpretation questions by email
- Interpretations that effect all projects will be published [here](#).
- Interpretations will provide guidance for credit submissions in order to meet the credit intent and policy goals.
- Interpretations will not contain any significant changes to REAP or to add any new requirements
- Each interpretation will undergo departmental review prior to being issued

## REAP INTERPRETATIONS

### Interpretation #1

#### *M&R Credit 1.1: Responsibly Sourced Materials*

##### **Clarification:**

For the purposes of this credit “Insulation” means either the thermal insulation in the exterior walls or the project’s acoustic insulation.

### Interpretation #2

#### *H&W P2 Low Emitting Products*

**Requirement:** an additional compliance pathway has been added for adhesives, sealants and sealant primers:

Add to the first bullet:

- “Or specify and use adhesives, sealants and sealant primers that are EcoLogo certified or do not exceed the current VOC limits in the South Coast Air Quality Management District (SCAQMD) Rule #1168 on the interior of the building.”

### Interpretation #3

#### *H&W P2 Low Emitting Products*

**Requirement:** regarding Master Painters Institute (MPI) GPS ratings for paints:

Add to the second bullet:

- “Or if no VOC limit is indicated for the product under GPS-2, show compliance with GPS-1. For GPS-1 and GPS-2 ratings, if the paint or coating is not on the MPI approved products list, compliance to VOC content and chemical component restrictions must be shown by submitting product information sheets”.